

GOVERNMENT OF ANDHRA PRADESH
A.P. STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

From:
The Director General,
State Disaster Response & Fire Services,
Andhra Pradesh, Vijayawada.

To:
The District Educational Officer,
Y.S.R Kadapa District.

Rc.No.1194/MSB/SOUTH/ZONE-4/KDP/2023, Dated: -02-2023.

Sir,

Sub:- A.P State Disaster Response & Fire Services Department - MSB Section - South - Zone-IV - Issuance of No Objection Certificate for Occupancy to the Existing Building of M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District - Regarding.

- Ref:-
1. Application of M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District.
 2. This Office Memo Rc.No.1194/MSB/KDP/2023, Dt:20-02-2023.
 3. MSB Inspection Committee/Officer Report Rc.No.08/RFO/Zone-4/2023, Dt:27-02-2023.

<< 0 >>

The Management has requested for issuance of No Objection Certificate for Occupancy to the Existing Building of M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District in the reference 1st cited.

- 2) The Management has constructed the Building with Ground Floor only with a height of 03.50 Mtrs., with total Built-up area of 545.00 Sq.Mtrs., for Educational Occupancy.
- 3) Previously, the management has not obtained Provisional No Objection Certificate from this Department and now applied for No Objection Certificate for Occupancy.
- 4) The Multi Storied Building Inspection Committee/Officer has inspected the premises of M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District on 26-02-2023, scrutinized the plans of above Existing Building and submitted the following report vide reference 3rd cited.

5) Particulars of the Building:

a) Name & Address of the Building	:	M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District.
b) Total Plot/Site Area	:	1500.00 Sq.Mtrs.,
c) No. of Blocks	:	One (01) Block
d) Height of the Building	:	03.50 Mtrs.,
e) No. of Floors	:	Ground Floor Only
f) Total Built-up Area	:	545.00 Sq.Mtrs.,
g) Type of Occupancy	:	Educational Occupancy

(Conted....2p)

6) Following are the Floor wise details of Existing Building total Built-up area.

Sl.No.	Floor	Built-up area (In Sq.Mtrs.,)	Type of Occupancy (as per Clause 3.1 part-IV of NBC, 2016)
1.	Ground	545.00	Educational
Total :		545.00	

7) The Management has provided the following Means of Escape.

Sl. No.	Details of Means of Escape	Minimum width Required (as per clause 4.4 Part-IV of NBC, 2016)		As found in the Inspection		Location	Deficit or Opinion of the Inspection Committee/Officer
		No.'s	Width (in Mtrs.,)	No.'s	Width (in Mtrs.,)		
1.	Internal Staircase	NA	NA	NA	NA	NA	-
2.	External Staircase	NA	NA	NA	NA	NA	-
Total:		-	-	-	-	-	-

8) The details of Occupant Load per Unit and Exit Width required and provided are furnished as below:

Sl. No.	Floor	Built Up Area (In Sq.Mtrs.,)	No. of Occupants	Means of escape Required (as per clause 4.4, Part-IV of NBC, 2016) in Mtrs.,	As found in the Inspection (in Mtrs.,)	Deficit or Opinion of the Inspection Committee/Officer
1.	Ground	545.00	136	Doors Required	Sufficient No of Doors Provided	Nil
TOTAL		545.00				

9) Further, we submit that, the Builder has provided the following Fire Fighting systems as per Table-07 of NBC, 2016.

Sl. No.	Fire Fighting Installations	Required	As found in the Inspection	Deficit or Opinion of the Inspection Committee/Officer
1.	Fire Extinguishers	06 No.'s	06 No.'s	Nil

10) Electrical Safety:

Sl.No.	Description	Compliance
1.	Whether Provided MCB's for each Floor ?	Yes
2.	Whether provided Emergency lighting at Corridors/Common passages and Staircases with UPS backup ?	Yes

11) The Management has provided minimum Fire Safety measures as per Table-7 of Part-IV of NBC-2016 and the Inspection Committee/Officer has tested the fire safety systems and found in working condition.

12) The Management is responsible all risks involved in case of Fire Accident.


13) In view of the above and based on the recommendation of the Inspection Committee/Officer, the No Objection Certificate for Occupancy is hereby issued to the M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District.

(Conted....3p)

14) It is informed that, the management is requested to maintain the following conditions compulsorily for safety purpose.

Sl.No.	As Builder	As Occupant	As Security Personnel
1.	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3.	Addition/alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4.	This No objection Certificate for occupancy is only in fire safety point of view.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

15) This No Objection Certificate for Occupancy is valid for a period of Five (05) years only from the date of issue of this letter to the management of M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District. It is the responsibility of the Builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated.13-08-2021 and G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated.25-10-2021, two (02) months before expiry of this No Objection Certificate.


 Additional Director General of Police, C.I.D,
 (HFAC) Director General,
 State Disaster Response and Fire Services,
 Andhra Pradesh, Vijayawada.

Copy to the Management, M/s Dalmia Vidya Mandir School, Located at Dalmia Cement (Bharat) Limited, Chinnakomerla Village, Mylavaram Mandal, Y.S.R District.
 Copy to the Regional Fire Officer, Zone-IV, Kurnool
 Copy to the District Disaster Response & Fire Officer, Y.S.R District.